

Addendum 1

File	Tender	Tender No.
219557-1	Big Sound Marina Improvements	219557

Date	Owner
August 25, 2020	Town of Parry Sound

Message to Bidder

SP1.1 The requirement to submit a “Statutory Declaration of Tenderer” is removed from the submission requirements.

Mooring Cleats “Flip-up aluminum mooring cleats” may be substituted for 10” cast aluminum fixed wing cleats. The bidder shall clarify type of mooring cleats proposed in design brief submission.

Electrical Ground Fault Ground fault leakage testing shall be included for re-routed Dock “A” feeder should the provisional work be included in the Contract. The Contractor shall perform a cable insulation test on the existing underground cable prior to commencement of relocation work and test results shall be submitted to Engineer for review. Any repair work deemed necessary will be considered outside of the scope of work of the Contract.

Concrete Testing Due to the limited quantity and use of concrete for the approach slab, the Contractor may forgo third-party testing during placement provided they submit an approved mix design/certificate of conformance from supplier. At the Engineer’s discretion, core testing may be required within the maintenance period at the Contractors expense.

Registration All Bidders are reminded to register with the office of the Consulting Engineer in accordance with Item 1.7 of the Instructions to Bidders.

Tender Receipt Bidders are reminded Tenders will be received at the office of the Town of Parry Sound 52 Seguin Street, Parry Sound, Ontario up to the Closing Time and Date of Tenders. Tenders received after the Official Closing Time will not be considered. Bidders are responsible for contacting the Town of Parry Sound to arrange delivery of the tender package.

Tender Opening Tenders will be opened publicly following the Tender Closing. A link will be provided for a virtual meeting prior to the Tender Closing.

Terms & Conditions

Except as to and to the extent that they are amended by the foregoing, all terms and conditions of the tender document remain in full force and effect, and time shall be of the essence.

Directions to Bidder

The Bidder shall:

1. sign this Addendum in the space provided below and submit this Addendum to the Owner in the same envelope as the Tender
2. enter this Addendum number in the Tender Form

Signature of Bidder

Date